



V J T I

Veermata Jijabai Technological Institute

(Central Technological Institute, Maharashtra State, INDIA)

H. R. Mahajani Marg, Matunga, Mumbai 400019

Tel.No. +91 22 24198101-02 Fax: +91 22 24102874

www.vjti.ac.in

Ref No. VJTI/Maintenance/ 362 /2026

Date: - 24 APR 2026

QUOTATION NOTICE

M/s.

.....

.....

Subject: - Emergency work of providing MCCB Panel Board near Structural Engg. Dept.

Enquiry Issue Date: - 24.04.2026 ✓

Last date of Submission: - 27.04.2026 at 3:00 PM ✓

Estimated Cost: Rs. 6,31,730/- (Including GST)

Dear Sir,

The Institute intends to undertake the work "Emergency work of providing MCCB Panel Board near Structural Engg. Dept." for which sealed quotations are invited. You are requested to quote the rates/price/cost in Annexure - I (BOQ).

TERMS & CONDITIONS

1. Quotation submission

- ✓ Sealed quotation, addressed to Director, VJTI; shall be posted or submitted at First Floor, Inward Section, VJTI, H. R. Mahajani Marg, Matunga, Mumbai 400019, in person so as to reach this Office on or before the due date and time.
- ✓ The sealed envelope shall be superscripted with Reference No. mentioned overleaf.
- ✓ Quotations must be submitted either on the official letterhead of the firm/vendor/company/organization, OR on uploaded BOQ with quoted rates. The quotation should be duly signed and stamped with the company stamp and seal on every page; else the quotation will be rejected outright.
- ✓ Please mention your GST, PAN and any other relevant identification /registration numbers.
- ✓ Please submit the BOCW Registration certificate if employing 10 or more workers, else submit the undertaking in the attached format along with quotation.
- ✓ If the due date turns out to be a holiday for unforeseen reason, quotation should be accepted on the next working day.
- ✓ The quotation should be valid for a period of 90 days.
- ✓ The rate/price/cost quoted should be inclusive of all items, labour charges, transportation cost etc.

Heumaysi

2. Payment



- Payment after the satisfactory completion of work will be made by bank transfer only.
- As per Institute policy, no advance payment will be made.

3. Acceptance of quotation

- Institute reserves the right of rejection of any or all the quotations without assigning any reasons.
- Canvassing in any form would lead to rejection of quotations.
- Quotations received after the due date will not be considered.
- Quotations without Signature and Stamp / Seal are likely to be rejected.
- Terms other than this may be specified separately.

4. Additional Terms & Conditions

- The contractor should have experience in completion of similar type of work costing minimum 60% of estimated cost of the work during the last three years.
- The VJTI Hostel premises should be inspected on any working day within office hours before submitting the quotation. A site visit form must be obtained from the maintenance section and attached along with the quotation.
- The experienced/qualified Supervisor (Diploma /Degree Civil Engineer) should be present at the worksite when work is in progress.
- All the debris generated from the works is to be removed by the Contractor. It should be disposed of away from the Institute premises following Municipality rules with all leads and lifts.
- The work may be carried out on all days from 8.00 AM to 6.00 PM. For working in late hour's Dean (ID & M) permission shall be obtained.
- Works should be completed within 60 calendar days from the date of work order.
- A penalty of Rs.500/- per day will be levied if work is delayed.
- Variation in quantity or extra items shall be executed only after prior approval of competent authority (Dean ID & M / Director)
- In the event that the bidder quotes an amount lower than the estimated cost, the bidder shall be liable to pay Additional Security Deposit (ASD), as stipulated under the prevailing PWD norms.



Dean (ID & M)

Annexure - I

Name of Work: - Emergency work of providing MCCB Panel Board near Structural Engg. Dept.

Sr. No.	CSR Ref No.	Description	Qty	Unit	Rate	Amount
1	5-7-5	Providing & erecting floor/wall mounting, MCCB panel board, with door, suitable for 4 pole incoming 250A, 12 ways 4 pole outgoing, up to 100A MCCBs on iron frame, as per specification no. SW-MCCBPB. (Excluding MCCBs) Panel Fabricated with 1.6mm. Indoor type-Dust and Vermin proof, free standing. Powder coated with Siemens gray shed.	2	Each		
2	5-7-15	Providing & erecting incoming and outgoing cable alleys suitable for MCCB panel board with door, 250A incoming and 12 way outgoing or 400A incoming and 6/8 way outgoing made from CRCA sheet 1.6 mm thick duly powder coated and having vertical insulated partition for shielding between the shared face of cableway and DB complete.	2	Set		
3	5-7-17	Providing & erecting prewired meter module suitable for MCCB panel board with CTs and emfs VIF meter. VAF Meter with CTs	2	Set		
4	6-7-5	Supplying & erecting LED type indicating pilot lamp with LED colours red / yellow / green, 230 / 250V on provided box / panel with necessary material, wiring & connections etc.	3	Each		
5	5-5-3	Providing & erecting 3 Pole MCCB, 415V, 200A, rated short-circuit breaking capacity 25 kA ($I_{cs}=100\%$ of I_{cu}), adjustable thermal (overload) setting and adjustable magnetic setting with provided leads, provision for installation of shunt/UV/trip alarm contact. MCCB should have phase barriers both sides, with insulation withstand capacity 800V, no line-load bias in provided enclosure/panel as per specification no. SW-MCCB 1) For use of 4 pole MCCBs in place of 3 pole MCCBs add 20% in rate of 3 pole MCCB.	2	Each		

Harmay



Annexure - I

Name of Work: - Emergency work of providing MCCB Panel Board near Structural Engg. Dept.

6	5-5-1	Providing & erecting 3 Pole MCCB, 415V, up to 100A, rated short-circuit breaking capacity 25 kA (Ics=100% of Icu), adjustable thermal (overload) setting and fixed magnetic setting with provided leads, provision for installation of shunt/UV/trip alarm contact. MCCB with phase barriers on both sides, insulation withstand capacity 800V, no line-load bias in provided enclosure/panel as per specification no. SW-MCCB 1) For use of 4 pole MCCBs in place of 3 pole MCCBs add 20% in rate of 3 pole MCCB.	9	Each		
7	5-3-13	Supplying, erecting & marking FP MCB 40A to 63A, with rated short - circuit breaking capacity (Icn) 10kA in provided distribution board as per specification no. SW-MCB	2	Each		
8	5-3-7	Supplying, erecting & marking DP MCB 6 A to 32 A, B-series with rated short - circuit breaking capacity (Icn) 10kA in provided distribution board as per specification no. SW-MCB	2	Each		
9	R3-ME-1-9	Bus bar chamers, using CRCA Sheet steel SWG 16, powder coated, rust protected enclosure. IP protection for chamber shall be IP43. Bus bar supports shall be SMC (each at every 300mm). Incoming and outgoing Cable termination provision shall be provided with 3mm undrilled gland plate. Colour shade shall be RAL 7032 Smoke gray as per IS 5. 200 /250A TPN with tinned copper bars of size 40 x 5 mm.	1	NOS		
10	R3-ME-1-31-b	SUPPLY & INSTALLATION OF ANGLE IRON FRAME WORK (TS-7) 40 x 40 x 5 mm of M.S.angle.	8.4	Mtr		

Yamaya

Annexure - I

Name of Work: - Emergency work of providing MCCB Panel Board near Structural Engg. Dept.



11	R3-ME-1-1-m	Switch Fuse Unit (SP-ME-TS-3): SFU with rewireable fuses (porcelain fuse unit) as per IEC 60947 Part 1 & 3 / IS 13947 part 1 & 3 to be enclosed in CRCA Sheet steel 18/20 SWG standard with powder coated, rust protected (if 16/18 SWG/1.62/1.21 mm Nos available) with PVC insulated cu wires for interconnection, bus bar, earthing terminal, and all other accessories to complete the work. SFU shall be wall/column mounted. Enclosure shall be weather proof. Colour shade shall be as per IS 5. MS angle iron frame to mount the unit is included. IP for enclosure shall be IP43 for Indoor unit and IP 55 for Outdoor unit 100 Amp. 415V TPN Switch fuse unit with CRCA sheet steel powder coated enclosure with rewireable fuses.	1	Nos		
12	7-2-35	Supplying, erecting & terminating FR XLPE insulated, galvanised steel formed wire armoured (strip) cable 1100 V, 4 core 25 sq. mm. copper conductor complete erected with glands & lugs, on wall/trusses/ pole or laid in provided trench/ pipe as per specification no. CB-LT/CU	100	m		
13	7-2-12	Supplying, erecting & terminating FR XLPE insulated, galvanised steel formed wire armoured (strip) cable 1100 V, 2 core 16 sq. mm. copper conductor complete erected with glands & lugs, on wall/trusses/ pole or laid in provided trench/ pipe as per specification no. CB-LT/CU	40	m		
14	9-1-5	Supply, installing, and testing of maintenance free earthing comprising of electrode of 17.2 mm diameter Low Carbon Steel with 250-micron molecular copper bonded earthing rod of Length 3m along with Carbon based environment friendly back fill ground enhancing compound required to fill up the excavated earth with required quantity (min. 125kg) complete, and recording the results specification no. EA-MF	2	Each		

Humayun 

Annexure - I

Name of Work: - Emergency work of providing MCCB Panel Board near Structural Engg. Dept.

15	9-2-2	Supplying and erecting copper strip of required sizes used for earthing on wall and/or any other purpose with necessary aluminium clamps fixed on wall painted with bituminous paint with joints required as per specification no EA-EP. 25 x 3 Cu Strip (For 1 mtr = 1.33 kg)	20	Kg		
		Total Basic Amount				
		Add CGST 9%				
		Add SGST 9%				
		Total Amount including GST 18%				


Dean (I & M)




V J T I
Veermata Jijabai Technological Institute
(Central Technological Institute, Maharashtra State, INDIA)
H. R. Mahajani Marg, Matunga, Mumbai 400019
Tel.No. +91 22 24198101-02 Fax: +91 22 24102874
www.vjti.ac.in

□

SITE VISIT FORM (to be attached with quotation)

Name of Work: - Emergency work of providing MCCB Panel Board near Structural Engg. Dept.

I undersigned Mr. _____ from M/s. _____

Have attended the site visit on _____ to understand
the scope of work in presence of institute engineer / representative.

Mr./Ms. _____.

For & on behalf of _____

Seal of the contractors